

TRIMO D.O.O.

PRIJATELJEVA CESTA 12
8210 TREBNJE | SLOVENIA
T: +386 (0)7 34 60 200
F: +386 (0)7 34 60 127
TRIMO@TRIMO-GROUP.COM
WWW.TRIMO-GROUP.COM

Date: 08.07.2022

Subject: VOCs statement: Comparison with limit value of EMICODE

To whom it may concern:

We hereby declare that Trimo d.o.o. has performed analysis and measurements of emissions of volatile organic compounds (VOC) for the products **Qbiss One and Trimoterm**. All tests have been carried out in an accredited test laboratory according to EN 16516 and ISO 16000-6.

Trimo declares that all measurements and compounds content for **Qbiss One and Trimoterm** products with typical internal steel sheet have been found to be below the minimum levels required for building materials for indoor use, according to EMICODE regulation for classification EC 1 PLUS.

Parameter	Value for EC 1 PLUS
TVOC 3 days (EN 16516)	$\leq 750 \mu\text{g}/\text{m}^3$
TVOC 28 days (EN 16516)	$\leq 60 \mu\text{g}/\text{m}^3$
TSVOC 28 days (EN 16516)	$\leq 40 \mu\text{g}/\text{m}^3$
Sum without NIK/LCI 28 days	$\leq 40 \mu\text{g}/\text{m}^3$
R-value 28 days	≤ 1
Formaldehyde 3 days	$\leq 50 \mu\text{g}/\text{m}^3$
Acetaldehyde 3 days	$\leq 50 \mu\text{g}/\text{m}^3$
Sum Formaldehyde + Acetaldehyde	$\leq 0,05 \text{ ppm}$
Sum carcinogens 3 days	$\leq 10 \mu\text{g}/\text{m}^3$
Sum carcinogens 28 days	$\leq 1 \mu\text{g}/\text{m}^3$

*We do not have licence to use protected trademark label EMICODE.

Should you require any further clarifications or information do not hesitate to contact us.

Robert Ajdič
Head of Quality department