

TRIMO D.O.O.

PRIJATELJEVA CESTA 12
8210 TREBNJE | SLOVENIA
T: +386 (0)7 34 60 200
F: +386 (0)7 34 60 127
TRIMO@TRIMO-GROUP.COM
WWW.TRIMO-GROUP.COM

Date: 08.07.2022

Subject: VOCs statement: Comparison with limit value of French VOC and CMR regulation

To whom it may concern:

We hereby declare that Trimo d.o.o. has performed analysis and measurements of emissions of volatile organic compounds (VOC) for the product **Qbiss One and Trimoterm**. All tests have been carried out in an accredited test laboratory according to EN 16516 and ISO 16000-6.

Trimo declares that all measurements and compounds content for **Qbiss One and Trimoterm** products with typical internal steel sheet have been found to be below the minimum levels required for building materials for indoor use, according to:

- Decree of March 2011 (DEVL1101903D) and Arrete of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A)

French VOC Regulation Parameter	Limit value after 28 days
TVOC	< 1000 µg/m ³
Formaldehyde	< 60 µg/m ³
Acetaldehyde	< 200 µg/m ³
Toluene	< 300 µg/m ³
Tetrachloroethylene	< 250 µg/m ³
Ethylbenzene	< 750 µg/m ³
Xylene	< 200 µg/m ³
Styrene	< 250 µg/m ³
2-Butoxyethanol	< 1000 µg/m ³
1,2,4-Trimethylbenzene	< 1000 µg/m ³
1,4-Dichlorobenzene	< 60 µg/m ³

- Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A).

CMR Parameter	Limit value after 28 days
Benzene	< 1 µg/m ³
Trichloroethylene	< 1 µg/m ³
Dibutylphthalate (DBP)	< 1 µg/m ³
Diethylhexylphthalate (DEHP)	< 1 µg/m ³

TRIMO

Should you require any further clarifications or information do not hesitate to contact us.

Robert Ajdič
Head of Quality department



2