

Attestation

LEED v4, v4.1 BETA, and v5

On the 12th of December 2025, Eurofins Product Testing A/S received a sample of a sandwich panel with the product name:

Trimoterm

supplied by

Trimo d.o.o.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2025-00755802_A_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4, LEED v4.1 BETA (November 2025), and LEED v5 (November 2025) projects in Europe by showing compliance with the specifications for VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4.1 BETA (November 2025) and LEED v5 (November 2025) by complying with the German AgBB Testing and Evaluation Scheme (2024), showing an overall R-value ≤ 1 , having a TVOC according to EN 16516 $\leq 1,000 \mu\text{g}/\text{m}^3$, a sum of VOC without LCI $< 100 \mu\text{g}/\text{m}^3$, and a formaldehyde emission $\leq 10 \mu\text{g}/\text{m}^3$; all after 28 days.
- The requirements of LEED v4 and LEED v4.1 BETA by complying with:
 - The requirements of Indoor Air Comfort Gold v2026 (January 2026).

26 March 2026



Rasmus Verdier
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.