

Date: 04.12.2024

Subject: VOCs statement: Comparison with limit value of Italian CAM Regulation

To whom it may concern:

We hereby declare that Trimo d.o.o. has performed analysis and measurements of emissions of volatile organic compounds (VOC) for the products **Qbiss One and Trimoterm**. All tests have been carried out in an accredited test laboratory according to EN 16516 and ISO 16000-6. The testing methods are accredited in accordance with EN ISO/IEC 17035.

Trimo declares that all measurements and compounds content for **Qbiss One and Trimoterm** products with typical internal steel sheet have been found to be below the minimum levels required for building materials for indoor use, according to Decree 11 October 2017 (GU n.259 del 9-11-2017).

Parameter	Limit value after 28 days
TVOC	< 1500 µg/m ³
Formaldehyde	< 60 µg/m ³
Acetaldehyde	< 300 µg/m ³
Toluene	< 450 µg/m ³
Tetrachloroethylene	< 350 µg/m ³
Ethylbenzene	< 1000 µg/m ³
Xylene	< 300 µg/m ³
Styrene	< 350 µg/m ³
2-Butoxyethanol	< 1500 µg/m ³
1,2,4-Trimethylbenzene	< 1500 µg/m ³
1,4-Dichlorobenzene	< 90 µg/m ³
Benzene	< 1 µg/m ³
Trichloroethylene	< 1 µg/m ³
Dibutylphthalate (DBP)	< 1 µg/m ³
Diethylhexylphthalate (DEHP)	< 1 µg/m ³

Should you require any further clarifications or information do not hesitate to contact us.

Robert Ajdič
Head of Quality department